

Use of Additional Substances in Systems for Refrigeration and Air Conditioning

- Due to the already complex physical and chemical processes taking place in a refrigeration circuit,
- with a view to the long term stability of oil and refrigerant,
- as reliability of the compressor could be affected,

we do not recommend the use of additional substances like leak detection additives, anti-acid additives ... etc.